

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl2) (ppm)	4	4	1.66	1.2	1.97	2018	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	41	35	49	2018	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	87	45	87	2018	Yes	By-product of drinking water disinfection
Total Organic Carbon (% Removal)	NA	TT	44	NA	NA	2018	No	Naturally present in the environment
Inorganic Contaminants								
Barium (ppm)	2	2	.008	NA	.022	2018	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	.8	.52	.98	2018	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate [measured as Nitrogen] (ppm)	10	10	.98	.22	8.9	2018	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Microbiological Contaminants								
Total Coliform (RTCR)	NA	TT	NA	NA	NA	2018	No	Naturally present in the environment
Turbidity (NTU)	NA		100	NA	NA	2018	No	Soil runoff
Volatile Organic Contaminants								
Not Detected								
Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source	
Inorganic Contaminants								
Copper - action level at consumer taps (ppm)	1.3	1.3	.11	2018	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	
Inorganic Contaminants								
Lead - action level at consumer taps (ppb)	0	15	1.3	2018	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	